

Lab Report

Upper Guadalupe River Authority

Date: 5/16/2019

125 Lehmann Dr. Suite 100, Kerrville, TX 78028

(830) 896-5445

TCEQ State Lab ID: 48145

CLIENT: City of Rocksprings
PO Box 796
Rocksprings, TX 78880
cityclerk@swtexas.net; peter.duran@sonora-texas.com; jcg8965@gmail.com
Ph: 8306834105

Lab Order: 1905229

Project: City of Rocksprings

System ID No: 0690012

Lab ID: 1905229-001
Collection Date/Time: 5/14/2019 8:30:00 AM
Sample Site: 602 N Cedar St
Source:
Sampled By: Peter R Duran
Sample Type: Construction
Field C12 Residual: 1.26 mg/L

Analyses	Result	PQL	Qual	Units	DF	Date Analyzed
BACTERIA ANALYSIS						
Method : SM 9223 B (N)						
E. coli	Not Found	1		P/A	1	5/14/2019 3 20 00 PM
Total coliforms (N)	Not Found	1		P/A	1	5/14/2019 3 20 00 PM

Signature: 
Nicole Shepherd, Lab Manager

Test Methods: Standard Methods for the Examination of Water and Wastewater; EPA Methods for Water and Wastewater; ASTM Int'l Standard Test Methods; Hach Methods



NELAP Accredited by TCEQ
For a list of Fields of Accreditation and current NELAP certificate, visit the Lab Services section of www.ugra.org

Confidentiality Statement: This is a confidential report for use by the addressed customer or authorized agent. This report may not be reproduced except in full.

Compliance Statement: All laboratory analyses performed in connection with the generation of the data set forth in this report were undertaken in accordance with requirements applicable to the laboratory methods used, unless otherwise noted in an attached Case Narrative. Any known problems/ anomalies observed by this laboratory (and if applicable, laboratories subcontracted through this laboratory) that might affect the quality of the data have been identified in the Case Narrative. Results shown relate only to the samples tested. Any known problems associated with the quality of the samples have been identified in the Case Narrative. All required Quality Control associated with the samples was acceptable unless the result is qualified with a "Q" flag or otherwise noted in the Case Narrative. The use of the measured values in this report for regulatory compliance purposes must be evaluated by, and is solely the responsibility of, the customer.

Quality Control sample results available upon request.

Suffix: (N) - NELAP Accredited Analysis

Qualifiers: Q - Data qualified; see Case Narrative. All required Quality Control was acceptable unless the result is flagged with a "Q" or otherwise noted in the Case Narrative.

Abbreviations: PQL - Practical Quantitation Limit, DF - Dilution Factor

**Boil Water Notice Rescinded
5-21-19**

On 5-13-19, the Texas Commission on Environmental Quality required the City of Rocksprings public water system, 0690012, to issue a Boil Water Notice to inform customers, individuals, or employees that due to conditions which occurred recently in the public water system, the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes.

The public water system has taken the necessary corrective actions to restore the quality of the water distributed by this public water system used for drinking water or human consumption purposes and has provided TCEQ with laboratory test results that indicate that the water no longer requires boiling prior to use as of 5-20-19.

If you have questions concerning this matter, you may contact City of Rocksprings at 830-683-4105 Rocksprings, Tx 78880. Water samples were taken and sent of the next available working day. All Samples came back negative for E. Coli and Total coliform.